



OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.



Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123

C.NO: 18/DFO/SRFS/BNG-2026.

"Annexure-2"

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Service
Sarjapura Road Fire Station,
Bengaluru-560 035.

Date: 16/03/2026

To,

The Authorized Signatory

M/s.New Macaulay English School,
Kadaagrahara Main Road, Somapura Gate,
Opp Trinity Apartment, Sarjapur Road,
Bangalore-560 087.

Sir,

Sub: Issue of "Fire Safety Compliance Certificate" with respect to fire prevention, fighting and evacuation measures maintained at "M/s. New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp. Trinity Apartment, Sarjapur road, Bangalore-562 125"

Ref: 1) This office FSR No.12/Dfo/SRFS/Bng/FSR/2026. Dt:-16-03-2026.

2) Your request letter dated: 10-03-2026.

<<<>>>

With reference to the above cited subject, as per reference (1) a conditional Fire Safety Recommendation was issued to the premises "M/s. New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp Trinity Apartment, Sarjapur road, Bangalore-562 125" with a Condition to fulfill the recommendations and compliance the same within 3 months,

With reference cited (2) above, the management of "M/s New Macaulay English School, had requested for the fire safety compliance report from our department. In this regard the above addressed educational building was inspected by FSO Sarjapur road on 10/03/2026 for issue fire safety Compliance report.

Under the above circumstance the Karnataka Fire & Emergency Services Department is issuing the "Fire Safety Compliance Certificate" to. of "M/s New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp Trinity Apartment, Sarjapur road, Bangalore-562 125" Subject to proper maintenance of fire fighting installations in the good working conditions and arrange for 40% of staffs/ employees are training within 03 months from the date of issue of this report. "This report is valid for one year from the date of issue of this report and is renewable without fail".




Yours faithfully,

16/3/26

DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560 035.

Copy to fire station officer sarjapur road fire station



**OFFICE OF THE DISTRICT FIRE OFFICER
SARJAPUR ROAD FIRE STATION
KAIKONDRAHALLI BANGALORE-560 035.**

Email:dfosarjapur99@gmail.com

Telephone No: 080-25746123



C.NO: 18/DFO/SRFS/BNG-2026.

"Annexure-2"

OFFICE OF THE DISTRICT FIRE OFFICER
Karnataka State Fire & Emergency Service
Sarjapura Road Fire Station
Bangaluru-560 035.

Date: 16/03/2026

To,
The Authorized Signatory
M/s. New Macaulay English School,
Kadaagrahara Main Road, Somapura Gate,
Opp. Trinity Apartment, Sarjapur Road,
Bangalore-560 087.

ANNEXURE-B

Group B Educational Buildings

Sub: Issue of 'Fire Safety Recommendation Certificate' with respect of fire prevention, fire fighting and evacuation measures required at "M/s. New Macaulay English School, Kadaagrahara Main Road, Somapura Gate, Opp Trinity Apartment, Sarjapur Road, Bangalore-562 125.


Ref: 1) Your Request Letter. Dated: 10/03/2026.
2) C.NO.12/FSO/SRFS/BNG-2023. Dt:-15/03/2026.

><<>*@*<><<

With reference to the subject cited above, the premises at "M/s. New Macaulay English School, Kadaagrahara Main Road, Somapura Gate, Opp. Trinity Apartment, Sarjapur Road, Bangalore-562 125" as inspected by FSO Sarjapur road On **10-03-2026** with respect to fire prevention, fire fighting & evacuation measures to be complied in the above Premises and has submitted The details as Under.

A. Details of the building / premises :-

01	Name and Address of the Applicant.	:	The Authorized Signatory. M/s.New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp. Trinity apartment, Sarjapur road, Bangalore-560 087.
02	Name and Address of the premises.	:	M/s.New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp Trinity apartment, Sarjapur road, Bangalore-560 087.
03	Name and address of the Building owner	:	M/s.New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp Trinity apartment, Sarjapur road, Bangalore-560 087.



04	Number of buildings	:	One Building
05	Number of floors	:	Ground plus 2 upper floors.
06	<u>Floor-wise details of occupancy:-</u>		
	Ground floor	:	09 Class Rooms, 01 Reception Room, 01 Principal Office, 01 Account Office, 01 Computer Lab, 01 Sports Room, 01 Staff Room, 6 Rest Rooms.
	1 st floor	:	13 Class Rooms and 6 Rest Rooms.
	2 nd floor	:	08 Class Rooms, 01 Auditorium hall and 06 Rest Room.
07	Height of the building	:	09.80 Mtrs.
08	Site area	:	2,996.60 Sq mtrs..
09.	Built-up area of each floor:-		
	Ground floor	:	733.72 Sq. Mtrs.
	1 st floor	:	733.72 Sq. Mtrs.
	2 nd floor	:	733.72 Sq. Mtrs.
10.	Total built-up area	:	2,201.16 Sq. Mtrs.
11.	<u>Surrounding properties:-</u>		
	North (Front)	:	12.00 mtrs wide Kadaagrahara main road.
	South (Rear)	:	Vacant Land.
	East (side)	:	Vacant Land.
	West (side)	:	Bavisya building.
12.	<u>Set-back area available around the building :-</u>		
	North (Front)	:	Minimum 04.80 mtrs
	South (Rear)	:	02.50 mtrs
	East (side)	:	02.50 mtrs
	West (side)	:	02.50 mtrs



B. On inspection of this Industrial premises, the following fire prevention, fire fighting and evacuation measures recommended are considered absolutely essential from fire safety point of view :-

Sl. No. (1)	Details (02)	Existing (03)	Recommendations (04)
01.	Accessibility to the premises	The premise is accessible from 12.00 mtrs wide Kadaagrahara Village main road located on Northern side the road is hardened to carry the Weight of 45.000 Kgs.	Adequate
02.	No. of entrances	01 entrances / exit	Complied
03.	Width of entry / exit	Entrance 06.20 mtrs has been provided.	Adequate
04.	Diesel generators.	One generator of 25 KVA capacities have been installed on the open space available on the Northern side.	Complied
05.	No. of staircases available	Nos. of staircases : 01	Complied
		Width of staircases : 01.30mtrs	
		Width of treads : 30 cm	
		Height of risers : 15 cm	
		Nos. of riser per flight : 10	
		Height of handrails : 0.90mtrs	
		Head room clearance : 2.60 mtrs	
06.	Fire extinguisher	8 Nos. of ABC fire extinguishers, each Of 5 kg capacity has been provided in The Building.	Complied
07.	First aid Hose reel hose.	One Hose Reel Hose has been provided near the entrance gate, Hose Reel Hose of 19 mm size of adequate length to reach the farthest point of floor has been provided with shut off branch having a nozzle of 5 mm size. Have been Provided.	Complied
08.	Terrace tank over respective tower	10,000 liters capacity of terrace tank has been provided	Complied



	terrace.		
09.	At the terrace tank level with minimum pressure of 3.5 kg/cm ² .	A booster pump has been installed at the terrace level capable of delivering 900 liters of water per minute.	Complied
10.	Escape routes	Escape routes have been Marked in Which visibly to guide the students make to safer Places.	Complied
11	No Smoking Board	No smoking board has been displayed in English and kannada at inside the entry/exit of the esch floor.	Complied
12	Fire Siren	A Fire siren has been installed inside the premises to inform all the inmates in case of a fire emergency and evacuate the area.	Complied
13	Nominate one fire no Nodal Officer	One non teaching staff has been nominated as fire nodal officer for the school premises.	Complied
14.	Fire order	A notice board has been displayed the Action to be taken by the school staffs in Case of an emergency with Telephone Numbers of Sarjapur Road Fire Station i.e. 25746166 & 101 and telephone numbers of nearest Ambulance Service & Management Has been displayed.	Complied
15.	Fire fighting training	Not trained	The staff or employees Should be got trained in fire prevention And fire fighting evacuation measures at R.A.Mundkur Fire & Emergency Services Academy, B.G.Road, Bangalore-29.
16	General Fire precaution measures :- A. Explosive and flammable materials should not be stored in the store room, UPS room, Electrical panel area, class rooms, laboratory & electrical sum panel premises. B. Accumulation of combustible waste in and around the premises should be avoided. C. The exit ways shall be always kept clear without any obstruction.		

- D. Liquefied petroleum gas should be not stored in the building.
- E. The doors shall not be kept locked/latched during working hours and shall be free from obstruction.
- F. During the class hours the class room doors shall not be locked from inside to outside.
- G. As per Hon'ble Supreme Court order all teacher and staff shall be trained to handle safety equipment, initiate emergency evacuation and protect their students in the event of fire and other emergency and the school shall observe the Fire Safety day on April 14th of every year by conducting fire safety drills with co-ordinate with Fire Service Department.
- H. This Fire Safety Recommendation is issued from the fire prevention, fire fighting and evacuation measures. Karnataka State Fire & Emergency Services Department is not responsible for the ownership of the land, its location and other disputes, which may arise in due course.

Under the above circumstance, the Karnataka Fire & Emergency Services Department is issuing "Fire Safety Recommendation" at "M/s. New Macaulay English School, Kadaagrahara main road, Somapura Gate, opp Trinity Apartment, Sarjapur road, Bangalore-562 125" subject to condition and compliance of the above recommendations as shown in Column-4 of Part-B within 3 months and compliance from the undersigned.

"This Fire Safety Recommendation is valid for Only One Year from the date of issue and it is renewable."

All requirements recommended above are as per National Building Code-2016 Part-4 clause 3.1.3 of Fire and Life safety will have to be complied with mandatorily.

Yours faithfully,

16/3/26

DISTRICT FIRE OFFICER
Sarjapura Road Fire Station
Bengaluru-560 035.

Copy to fire station officer sarjapur road fire station