



Government of Karnataka
RURAL DRINKING WATER & SANITATION SUB-DIVISION OFFICE, ANEKAL
BANGALORE URBAN DISTRICT-562106

Annexure C

Appendix-XIII

PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

Vide No 07 Dated: 29/03/2026

Dated:30/03/2026

It is certified that an inspection team headed by **Vinay Kumar H.S, Assistant Engineer** from **Rural Drinking Water & Sanitation Sub-division, Anekal** inspected the **New Macaulay English School Kada Agrahara Main Road, Sompura Gate, Opp. Trinity Apartment, Sarjapura Road, Anekal Taluk,** on **30/03/2026**. checked the water test report Submitted by the school and found that the school has potable drinking water for students and staff of the Institution and is having provision for running water in the toilets and maintaining hygienic sanitation Condition in the school building & the campus as per norms prescribed by the Central /State/ U.T.Govt.

The above is valid for a period of **12 months**

Signature with Seal  Assistant Engineer
Name **Rural Drinking water and sanitation**
Sub Division Anekal
Designation : **Assistant Engineer**


Assistant Engineer
Rural Drinking Water & Sanitation Sub-division,
Anekal

To
New Macaulay English School,
Kada Agrahara Main Road,
Sompura Gate, Opp Trinity Appartment,
Sarjapura Road, Anekal Taluk,
Bengaluru-562125.



RURAL DRINKING WATER & SANITATION DEPARTMENT, GoK
Bengaluru Urban Divisional Laboratory-Banashankari, Bangalore-560070.
NABL Accredited Laboratory Bangalore urban

TEST REPORT

Address of the sampling location :- New Macaulay English School kada Agrahara Main Road, Sompura Gate, Opp. Trinity Apartment, sarjapura Road, Anekal Taluk, Bengaluru-562125.	Report date: 29/03/2026
	Report Number: 07
	Reference: TRF
	Sample code: 07
	Date of Sample collection: 25/03/2026
	Analysis start date: 25/03/2026
	Analysis completion date: 26/03/2026
Sample Particulars: R.O water	DISE Number: 202900417602
	Sample quantity: 1 Liter

Sl.No	Test	Results	Acceptable Limit IS 10500 : 2012 RA:2018	Permissible Limit IS 10500 : 2012 RA:2018	Protocol
Description: Colourless liquid					
1	pH Value @25°C Temp	6.9	6.5 – 8.5	No relaxation	IS 3025 (Part-11) : 2022
2	Specific Conductance, $\mu\text{S}/\text{cm}$ @25°C Temp	130.0	-	-	IS 3025 (Part-14) : 2013
3	Odour	Agreeable	Agreeable	Agreeable	IS 3025 (Part-5 & 6):2018
4	Colour, Hazen Units	< 1.0	5	15	IS 3025 (Part-4) : 2021
5	Turbidity, NTU	0.0	1	5	IS 3025 (Part-10) : 2023
6	Total Dissolved Solids, mg/l @180°C	80.0	500	2000	IS 3025 (Part-16) : 2023
7	Alkalinity as CaCO_3 , mg/l	30.2	200	600	IS 3025 (Part-23) : 2023
8	Total Hardness as CaCO_3 , mg/l	20.2	200	600	IS 3025 (Part-21) : 2009
9	Calcium as Ca, mg/l	4.9	75	200	IS 3025 (Part-40) : 1991
10	Magnesium as Mg, mg/l	2.0	30	100	IS 3025 (Part-46) : 2023
11	Chloride as Cl, mg/l	19.0	250	1000	IS 3025 (Part-32) : 1983
12	Sulphate as SO_4 , mg/l	Nil	200	400	IS 3025 (Part-24) : 2022
13	Fluoride as F, mg/l	Nil	1	1.5	APHA 24 th Edition
14	Nitrate as NO_3 , mg/l	12.7	45	No relaxation	APHA 24 th Edition
15	Iron as Fe, mg/l	Nil	1	No relaxation	IS 3025 (Part-53) : 2003

Remark: The above given sample conforms to the acceptable limits as per IS 10500:2012 drinking water specifications for the above mentioned parameters only.

Analysed by: Megha K.S
Senior Analyst/Junior Analyst

Authorized Signatory: Pavithra B.S
Technical Manager: Pavithra B.S



RDWSD/WQMSP/TeR/01

Note:

- 1) The above results relate only to the sample tested.
- 2) The report shall not be reproduced except in full without the prior approval of the Quality Manager.
- 3) Traceability: Traceability of measurements is established using CRMs traceable to National/International standards.
- 4) Samples will be discarded after 15 days from the date of report generation.
- 5) Decision rule is applicable as per the procedure mentioned in RDWSD/WQMSP/DR-01

---END---